




ATEX electric actuator Installation and maintenance user manual



Hazardous areas

INDEX

1.	CENTORK ELECTRIC ACTUATORS: INTRODUCTION	4
2.	SAFETY INSTRUCTIONS.....	4
3.	TRANSPORT AND STORAGE	4
3.1	Transport.....	4
3.2	Storage and commissioning.....	4
4.	CONDITIONS OF SERVICE FOR ELECTRIC ACTUATORS	5
4.1	Electric actuator: Main description and purpose	5
4.2	Temperature range	5
4.3	Actuator and motor duty service	5
4.4	IP protection degree.....	6
4.5	Painting and protection against corrosion.....	6
5.	MOUNTING TO THE VALVE	6
5.1	Pre-Installation Inspection.....	6
5.2	Output size	6
5.3	Output type.....	6
5.4	Mounting:	6
6.	ELECTRIC CONNECTIONS	7
6.1	Wiring diagram (electric manoeuvre).....	7
6.2	Terminal plan and wiring.....	7
7.	MANUAL OPERATION	8
8.	SETTING and preliminary test.....	9
8.1	Switching and signalling unit.....	9
8.2	Actuator and valve (Sense of rotation)	10
8.3	Motor and power supply (Sense of rotation).....	10
8.4	Closed position limit switch setting	10
8.5	Open position limit switch setting.....	11
8.6	Torque switching setting	11
8.7	Mechanical position indicator setting (optional).....	12
8.8	Potentiometer POT setting (optional).....	12
8.9	4-20 mA transmitter TPS setting (optional).....	12
9.	MAINTENANCE.....	13
9.1	After commissioning.....	13
9.2	Maintenance for service.....	13
9.3	Electric actuator's service life.....	13
10.	TECHNICAL SUPPORT	13
11.	SPARE LIST	14
	APENDIX: OUTPUT TYPES	15
	APENDIX: FASTEN BOLTS (CLASS 8.8)	17
	WIRING DIAGRAMS, TERMINAL PLANS, LEGENDS AND SYMBOLS	18
	APENDIX: CERTIFICATES.....	19
12.	NOTES	23

THIS USER MANUAL HAS BEEN DEVELOPED FOR **centork** ELECTRIC ACTUATOR 40A, 41A, 40B and 41B SERIES



CAUTION

centork Electric actuators are a high value devices. In order to prevent damage in their handling, setting and use it is essential to follow and observe all the points in this user manual, operate under actuators' designated use, and observe health and safety rules, standards and directives for devices and apparatus designed to operate in potentially explosives atmospheres, as other national regulations as well.

centork Electric actuators must be handled with care and caution.

IMPORTANT NOTE
The contents in this manual is subject to change due to the quality improvement without individual notice.

1. CENTORK ELECTRIC ACTUATORS: INTRODUCTION

The electric actuator is a device designed to be coupled to a general purpose industrial valve, to carry out its movement. The movement is stopped by limit switching or by torque (thrust) switching. Other applications should be consulted CENTORK before. CENTORK is not liable for any possible damages resulting from use in other than designated applications. Such risk lies entirely on the user.

2. SAFETY INSTRUCTIONS

The scope of this manual is to enable a competent user to install, operate, adjust and inspect a CENTORK electric actuator. These instructions must be observed, otherwise a safe operation of the actuator in no longer warrantee.

When handling electric equipment, the health and safety standards (EN 60.204, 73/23/EEC directives) and any other national legislation applicable must be observed. For works carried out in hazardous areas special regulations and directives must be observed; 89/655/EEC directive and EN 60079 standard. Areas classification, where devices and work take place under potentially explosives atmospheres, is a user responsibility, according to 1999/92/CE directive.



Work at the open actuator under voltage must only be performed if it is assured that for the duration of the work there is no danger of explosion. In other conditions actuator should be carry to a safe area.



As electric device, during electrical operation certain parts inevitably carry lethal voltages and currents (ELECTRICAL RISKS).

Works on the electrical system or equipment must only be carried out by a skilled electrician himself or by specially instructed personnel, in accordance with the applicable electrical engineering rules, health and safety Directives and any other national legislation applicable.

Electric actuators are powerful apparatus. A negligence handling might cause severe damages to valves, people, and actuator as well. Under no circumstances should any modification or alteration be carried out on the actuator as this could very well invalidate the conditions which the device was designed.



Under operation, motor enclosure surfaces can reach high temperatures (up to 100°C). Protection measures should be taken into account in order to prevent people and goods from it.

3. TRANSPORT AND STORAGE

3.1 Transport

- CENTORK electric actuators must be transported in sturdy packing. During transport measures should be adopt in order to prevent impacts, hits. CENTORK delivers its actuators ex-work.
- Hits or impacts against wall, surfaces or objects might cause severe damage on Electric actuator. In this cases, after such events, a technical inspection must be done by CENTORK technicians.
- Do not attach to the handwheel ropes or hooks to lift by hoist.

3.2 Storage and commissioning

- **Store in a clean, cool, dry and ventilated place. For other storage conditions or, and long time periods (More than 5 months) contact to manufacturer.**
- Check that electrical connection cover and switching and signalling unit cover and are correctly closed ant tight.
- Cable entries on electrical connection cover must be sealed. Protection plug supplied by CENTORK are only adequate for storing in dry and ventilated places, for short period of time. In other conditions **protection plug must be replaced with metallic plug sealed with PTFE tape.**




- Do not store the actuator directly on the ground!
- Cover it to protect it from dust and dirt. Cover the machined parts with suitable protection against corrosion.
- Do not handle it by picking it up by the handwheel.
- **Just when commissioning, CENTORK recommend a visual inspection in order to detect any anomaly caused during the transport, and during the storage as well. Checking should include a visual inspection of electric compartment, and switching and signalling unit .**
- For further details, consult the technical sheet 'Conditions for Transport and Storage'.

4. CONDITIONS OF SERVICE FOR ELECTRIC ACTUATORS

4.1 Electric actuator: Main description and purpose

- Electric actuator is an apparatus or device formed by a electric motor, coupled to a main gearbox unit, which transmits motion and torque to valves.
- A switching and signalling unit, inside of Electric actuator, allows to provide torque and limit switching operation. **Limit and torque switches must be included on the Electric manoeuvre in order to prevent overloads on valve and actuator which might cause a fatal damage on valve and actuator.**
- Electric actuator must be controlled by a external electric cabinet with all elements needed (Transformer, contactors, relays, lamps, fuses...), designed according to actuator technical features and
- Electric actuators actuators are provided with a declutchable manual override system in order to operate manually in case of emergency or fail of power supply.
- Electric actuator can be coupled directly to valve, or maybe, through gearbox units (Bevel, spur and worm gearboxes).



The electric actuator is a device designed to be coupled to a general purpose industrial valve, to carry out its movement. The movement is stopped by limit switching or by torque (thrust) switching. Other applications should be consulted CENTORK before. CENTORK is not liable for any possible damages resulting from use in other than designated applications. Such risk lies entirely on the user.

4.2 Temperature range

CENTORK Electric actuators work in a temperature range from -25°C to +70°C.

4.3 Actuator and motor duty service

Electric actuator has been designed for valve motorization which requires ON-OFF and inching (Modulating) duty service.

- ON-OFF duty service: Electric actuator has been designed as S2-15 min (Three phases motor) or S2-10 min (Single phases motors) duty cycle at nominal torque, according to IEC standards: Nominal torque is rated to 50% of max tripping torque (100%), value marked on actuator nameplates. Higher nominal torques can reduce the actuator's service life and S2 duty cycle.
- Inching or modulating duty service: Electric actuators has been designed as S4-25%, at 1.200-800 starts per hour, at nominal torque. Nominal torque is rated to 50% of max tripping torque (100%), value marked on actuator nameplates. Higher nominal torques can reduce the actuator's service life and S4 duty cycle conditions.

4.4 IP protection degree

- CENTORK Electric actuators are designed in their standard version with IP67 (acc. EN 60.529) environmental protection although IP68 protection may be supplied on request. **IP67 and IP68 protection degree is only guarantee employing proper protection plug and cable gland (For cable entries)**, according to IP degree (See chapter ELECTRIC CONNECTIONS) . It is necessary to observe storing and maintenance rules written on TRANSPORT AND STORAGE chapter as well.

4.5 Painting and protection against corrosion

- CENTORK has designed three protection degree: Standard protection, P1 and P2. For technical details, consult CENTORK.
- Electric actuator are coated with a epoxy- two components primer (Film thickness depends on protection class selected, actuators are coated with intermediates primers) followed by a polyurethane component paint coat. The standard colour is blue RAL 5.003. Other colours are possible (Option). Other film thickness under request.

5. MOUNTING TO THE VALVE

5.1 Pre-Installation Inspection

- Verify the actuators nameplate to insure correct model number, torque, operating speed, voltage and enclosure type before installation or use.
- It is important to verify that the output torque of the actuator is appropriate for the torque requirements of the valve and that the actuator duty cycle is appropriate of the intended application

5.2 Output size

Check whether actuator output flange suits the flange of the valve to be driven. The latter should have been designed following the ISO5210 or ISO5211 standard, for standard application, or following the customer's specifications, for special application.

5.3 Output type

Check that the type of flange-coupling of the actuator suits the valve to be driven (diameters and lengths). Those manufactured as Standard at CENTORK follow the ISO5210/5211 standards. Types of output drive:

- **Output type A:** If not otherwise specified in the order, it is supplied blank. The thread must be machined according to the stem of the valve to be driven. For the dismounting and machining of this type of output, see Appendix . Output type A models can withstand axial loads and torque
- **Output type B0, B1, B2, C:** It is supplied machined to the dimensions stated in the ISO 5210/5211 or DIN 3338 standard. Output type B and C models **cannot withstand axial loads**.
- **Output type B3, B4:** It is supplied blank. For the dismounting and machining of this type of output, see Appendix .

5.4 Mounting:

- Check size and the type of output match the valve to be driven.
- Degrease the mounting surfaces at actuator and valve thoroughly.
- Slightly grease the input shaft of the valve to be driven.
- Fit the actuator into the valve. In the event of a threaded output (type A), use the handwheel for turning the nut over the threaded stem.
- Do not lift the actuator by the handwheel
- The actuator may be mounted in any position. Before mounting, check proper orientation actuator and valve in order to simplify access to handwheel, switching and terminal compartments (Maintenance and start-up tasks).
- Using ISO Class 8.8 quality bolts, fasten crosswise controlling the applied torque according to the table in Appendix

6. ELECTRIC CONNECTIONS




CAUTION: Safety instructions on chapter 2 must be observed. Work on electrical system or equipment must only be carried out by skilled electrician, according to safety standards.

6.1 Wiring diagram (electric manoeuvre)



Electric actuator must be controlled by a external electric cabinet with all elements needed (Transformer, contactors, relays, lamps, fuses...) Wiring diagram should be designed according to electric actuator features. Electric actuator datasheet, supplied with the actuator, includes a **PROPOSED WIRING DIAGRAM**, delivered with other technical documentation. **The following points should be observed:**

- We recommend to switch off the corresponding contactor/relay always directly by the limit or torque switch (opening and closing). **Torque switches must be included on Electric/electric manoeuvre in order to protect actuator and valve from undesired overloads.** Each valve manufacturer decides whether the switching off at both ends is made by torque switching or by limit switching.
- The maximum delay for switching off the motor with the signal of the torque or limit microswitch cannot exceed 40 ms.
- **Torque and limit microswitches have 1NO+1NC contacts, only the same potential can be connected through both circuits. For different potentials, two double microswitches must be used.**
- Torque microswitches signals are **non-maintained signals**, when motor stops after a over-torque condition torque signals may reset (Non-maintained). Relays or another device must be employed (See wiring diagram)



- **Capacitors for single-phase A.C. motors are not delivered with electric actuators. They should be installed on electric cabinet (External) in a safe area, or capacitors should be Ex type, suitable for applicable hazardous area .** Each capacitor must be dimensioned according to motor voltage and power.



- CENTORK actuators are provided with **thermo-switches** mounted in the windings of the motor (TRM). **The protection of the motor and actuator is only achieved with a proper connection for these thermostats, it is recommended to switch off the corresponding contactor/relay always directly by this thermo-switches. Centork guarantee for the motor is not valid if this connection is not properly done.**

Features of electric and electronic components must be observed, they are listed on appendix. Wiring diagram are included on appendix: D0015X2 for A.C. three-phase, D0043X2 for A.C. single-phase.

6.2 Terminal plan and wiring

The electric connection diagram or terminal plan is depicted on Electric actuator datasheet, supplied with the actuator, and it can be found printed on a label inside of electrical compartment cover.



- Open the electrical cover.
- **Feed the cable(s) through the cable glands . Fix proper cable glands according to IP67 or IP68 protection degree.**



Figure 6.1



Figure 6.2



Figure 6.3





Figure 6.4

- A) Electric actuator with **Plug-socket connectors** (Figure 6.1) with screws
- Unscrew the attachment plate from the connection cover.
 - With a suitable screwdriver, connect the cables for the control signals according to the electric connection diagram. (Figure 6.1)
- B) Electric actuator with **Terminals connection** (Figure 6.2)
- With a suitable screwdriver (SD 0,6x3,5 DIN 5264-A), connect the cables for the control signals according to the electric connection diagram. (Figure 6.2 and Figure 6.4)

Caution!

- Connect the earth cable terminal  to the earth connection located inside of electric connection cover (M5 screw hole). Electric actuator has a external bolt in order to connect an external earth terminal.
- Once you have checked that the connections have been properly carried out, close the connection cover and check the proper connection, the state of the o-ring seal and the proper installation of the latter, greasing it slightly. Fasten the 4 screws crosswise.
- Fix proper cable glands according to IP67 or IP68 protection degree. **Replace the protection plug with suitable metallic protection plug sealed with PTFE** . (Figure 6.3) Tighten cable glands and protection plugs to ensure enclosure IP67 (IP68 if applicable).




7. MANUAL OPERATION

- CENTORK actuators are fitted with a handwheel for the manual actuation of the valve.
- In the case of simultaneous motorised and manual working, the motorised one will always be the preferential one.
- Once the handwheel has been engaged is not possible to disengaged, **the override engagement lever returns automatically to motor position when the motor is operated. Do not press the lever when motor is running.**



Engagement of manual operation:

- Turn the change-over lever 20° clockwise while slightly turning the handwheel.
- When you notice an increase in the resistance of the wheel, the manual control is engaged.
- Run the valve in the desired direction. Standard sense of rotation is clockwise to close. For greater operating speed you can connect any power tool, pneumatic or electric, to the hand-wheel shaft. The maximum speed allowed is 150 rpm.



8. SETTING AND PRELIMINARY TEST




- **Safety rules and standard should be observed (See SAFETY INSTRUCTIONS chapter)**
- Setting and preliminary test can only be done when finished the wiring and mounting on valve. Electric manoeuvre (Electric cabinet) and devices should be ready and checked.
- Both the torque and the limit switches setting must be carried out in accordance with the characteristics of the valve to be driven. **Each valve manufacturer decides whether the switching off at both ends is made by torque switching or by limit switching.**
- **If actuator has been supplied already assembled onto the valve by valve manufacturer, the settings made originally by the manufacturer should NOT be modified on site without the authorisation of the latter, otherwise, serious damage may be caused both to the valve and to the actuator.**

CENTORK recommend to move the valve to an intermediate position manually, -via handwheel device- (according to section 6) in order to execute the test routines described below, avoiding problems due to incorrect routines or user's mistakes.

Just when user finishes a setting routine, covers must be closed, checking their O-ring (Sealing) !


8.1 Switching and signalling unit



8.2 Actuator and valve (Sense of rotation)

Electric actuator and valve sense of rotation must be the same. Electric actuator sense of rotation criteria is CLOCKWISE TO CLOSE. Sense of rotation is critical for many components (Microswitches, potentiometer, 4-20 mA transmitter). **A correct operation cannot be warranty in case of different sense of rotation valve/actuator)**


- Operate the Electric actuator via handwheel (See Manual operation chapter).
- Check that running the handwheel clockwise, valve moves to close. If the turn direction is not correct, stop immediately and verify.



8.3 Motor and power supply (Sense of rotation)

When running to close, check that U shaft turns in clockwise rotation sense (See picture). At the same time electric actuator output shaft should turn in clockwise sense of rotation as well. If this does not happen, stop immediately!, check:

- For **three-phase A.C. motors**: Check that U-V-W phase sequence (Main voltage supply) is correct. Notice that U-V-W phases are wired to 1-2-3 motor contacts or terminals. Change two phases U-V-W on terminal blocks (e.g. U and V) and try it again.
- For **single-phase A.C. motors**: Verify the wiring (See figure)



8.4 Closed position limit switch setting

- Manually turn the valve to the desired CLOSED position.
- Disengaged **PUSHER SHAFT**: With a suitable screwdriver press the **PUSHER SHAFT** 3 mm and turn it 45°, ensure that it does not return to its original height (See figure 8.4.1)
- Note: Pusher shaft allow to engage/disengage the switching and signalling unit from Electric actuator gears. (Figures 8.4.1 and 8.4.2)
- Turn **U spindle** clockwise (Figure 8.4.3) until **Z spindle** turns Counter-clockwise (At this moment FRC microswitch triggers). Just before FRC microswitch was tripped, red arrow of **Z spindle** should be pointed to vertical: When **Z spindle** (Red arrow) turns to left the FRC microswitch is tripped.
- If, by accident, it has been carried on turning past the tripping of the FRC microswitch, turn **U spindle** in the opposite direction (counter-clockwise) until the Z spindle returns vertical (Figure 8.4.5)




Fig. 8.4.1

Switching and signalling unit engaged to actuator.




Fig. 8.4.2

Switching and signalling unit disengaged




Fig. 8.4.1




Fig. 8.4.2




Fig. 8.4.3




- ENGAGE **PUSHER SHAFT**: Turn back selector 'PUSHER'. Check that go back to its initial position (Figure 8.4.2). **This point is fundamental for the correct setting of the limit switches: Ensure that PUSHER shaft is correctly engaged.**

NOTE: For greater speed in long runs, small electric or pneumatic screwdriver can be used.

8.5 Open position limit switch setting

- Manually turn the valve to the desired OPEN position.
- Disengaged **PUSHER SHAFT**: With a suitable screwdriver press the **PUSHER SHAFT** 3 mm and turn it 45°, ensure that it does not return to its original height (See figure 8.4.1)
- Turn **A spindle** Counter-clockwise (Figure 8.5.1) until **B spindle** turns clockwise (At this moment FRA microswitch triggers). Just before FRA microswitch was tripped, red arrow of **B spindle** should be pointed to vertical: When **B spindle** (Red arrow) turns to right the FRA microswitch is tripped.
- If, by accident, it has been carried on turning past the tripping of the FRA microswitch, turn **A spindle** in the opposite direction (clockwise) until the **B spindle** returns to vertical. Figure 8.5.3)
- ENGAGE **PUSHER SHAFT**: Turn back selector 'PUSHER'. Check that go back to its initial position (Figure 8.4.2). **This point is fundamental for the correct setting of the limit switches: Ensure that PUSHER shaft is correctly engaged.**




8.6 Torque switching setting

CENTORK Electric actuators leave the factory tested and set for its Max. Torque (100%), as standard. Adjustment torque range is 60% up to 100% of Max. Torque rated on nameplates. **Guarantee is not valid if the user exceeds this range (60%-100%), or if torque microswitches are not employed.**



Torque mechanism design

Torque mechanism always acts as soon as actuator output torque exceeds the value set (Torque setting) It is used as protection throughout the whole valve travel and during the limit switch tripping. It also remains active during manual operation, thereby protecting the valve from any torque excess caused by the handwheel.



- When torque on valve shaft exceeds the value set, e.g. running to close, **T shaft** turns to the right (Pointing to FPC), at the same time central SHAFT releases (See figures 8.6.1 and 8.6.2). FPC microswitch is tripped. Automatically, or when actuator starts running to opposite direction, mechanism returns or resets. Notice that central SHAFT latches again. (Figure 8.6.3)

Torque setting Procedure:

- Using a No.17 wrench, turn the P Torque regulator or **Torque Limit Device** until the desired torque matches with the **S torque reference** arrow on the dial. (Figures 8.6.4 and 8.6.5)





Fig. 8.6.4

Fig. 8.6.5

8.7 Mechanical position indicator setting (optional)

Mechanical Position Indication dial turns between CLOSE and OPEN position depending on the model and valve stroke. This is achieved with the addition of a suitable gearing according to the number of turns per valve stroke. If the latter varies, the gearing must be changed.

- Run actuator to the CLOSED position.
- Unscrew the bolt and turn the dial with the symbol (CLOSED) until it matches with the mark on cover.
- Run actuator to the OPEN position, and proceed exactly with disc containing OPEN symbol.




8.8 Potentiometer POT setting (optional)

Limit switches must be set before!

Potentiometer is selected according to valve stroke. A suitable gearing unit reduce valve stroke (Number of turns) to less than one turn, this movement is measured by potentiometer located on switching and signalling unit.


- Run the actuator to the CLOSED position.
- With a suitable screwdriver, turn the **spindle (W)** of the potentiometer POT, counter-clockwise, to its top end.
- Check that potentiometer value is 0 Ohms.
- Run the actuator to the OPEN position.
- Check that potentiometer value reaches its maximum (Ohms)



CAUTION: The potentiometer is a high precision electromechanical device and should be handled carefully. It is necessary to use a suitable screwdriver for its setting.

8.9 4-20 mA transmitter TPS setting (optional)


- Limit switches must be set before.
- 4-20 mA transmitter are selected according to valve stroke. A suitable gearing unit reduce valve stroke (Number of turns) to less than one turn, this movement is measured by potentiometer, and converted to current signal by TPS transmitter. If valve stroke changes, TPS may not work properly.
- 4-20 mA TPS for ATEX versions: 2 wires mode. Type of protection: EEX ia IIC T6/T5/T4 según LCIE 90.C6099X



Procedure:

- Run the actuator to the CLOSED position (sensor in minimum signal).
- With a suitable screwdriver, turn the **spindle (W)** of the potentiometer **POT**, counter-clockwise, to its top end.
- Adjust the output current with the **ZERO (F)** trimmer potentiometer until its reading is close to 4 mA
- Run the actuator to the OPEN position (sensor in maximum signal).

Eje D: ajuste SPAN



Eje F: ajuste ZERO

- Adjust the output current with the **SPAN (D)** trimmer potentiometer until its reading is close to the maximum current of 20mA.
- Run the actuator back to the CLOSED position and check that the minimum current is 4 mA. If this is not the case, repeat previous points until optimum adjustment values are reached.



CAUTION: The TPS electronic position transmitter is a high precision electronic device and should be handled carefully. It is necessary to use a suitable screwdriver for its setting.

9. MAINTENANCE

CENTORK actuators are supplied greased from the factory for their lifetime, needing practically no maintenance.

9.1 After commissioning

- Check for damage on paint caused by transport, assembly or handling and repair the damage carefully in order to ensure complete protection against corrosion.
- Make sure that all the o-ring seals are correctly mounted and that the cable glands are firmly fastened, and protection plug for cable entry not used have been replaced with metallic protection plug sealed with PTFE tape, in order to ensure the IP67, IP68 protection.
- The most important condition for reliable service of the CENTORK actuators is the fact of having carried out a correct commissioning and set-up procedure.

9.2 Maintenance for service

CENTORK recommends for a preventive maintenance programme: Approximately 3 months after commissioning and then every 9/12 months:

- Check the correct tightening of the bolts between the actuator and the valve. Retighten according to section 2 if required.
- Take advantage of each revision to check the proper tightening of the covers, of the handwheel lock and the external electric connection.
- Check cable entries
- Visual inspection inside of switching and signalling, and electrical compartments.
- Contact with valve manufacturer in order to know about maintenance routines of valve.

In the event of infrequent service, perform a test run every 6 months in order to ensure the availability of service of the actuator.

9.3 Electric actuator's service life

- Electric actuator service life is rated to 20.000 cycles.
- Each cycle is formed by an opening manoeuvre (Valve close position to valve open position) and a closing manoeuvre (Valve open position to valve close position).
- 50 turns has been considered as standard valve stroke reference.


10. TECHNICAL SUPPORT

Each actuator is supplied with a datasheet on A4 format. The following is included:

- Electric actuator datasheet.
- The electric connection diagram for each actuator (also stuck inside the connections cover of the actuator).
- This electric actuator user manual.

For any claim or information request, the SERIAL NUMBER included on this datasheet or on the Electric actuator nameplates should be used. Electric actuator manufacturer address: See on Manual covers.

11. SPARE LIST



Code	Description
00	Actuator gearcase
01	Declutch lever subassembly
02	Handwheel subassembly
03	Motion measuring shaft subassembly
04	Torque switching shaft subassembly
05	Electrical cover
06	Switching and signalling cover
10	Electric motor
20	Torque regulator device
21	Main planetary gear (PTCS)
22	Spring absorber subassembly

Code	Description
30	Output flange
31	Spur gearbox
32	Output type A unit
33	Removable bush and shafts
40	Switching and signalling unit
41	4-20 mA transmitter TPS
42	Potentiometer
43	Gearing unit
44	Mechanical position indicator
50	Terminal and switches subassembly.
60	Plug cover
61	Rising stem protection cover tube

APENDIX: OUTPUT TYPES

OUTPUT TYPE A Size F-07 (ISO 5210)

Disassembly:

Employing a suitable tool, remove the retaining ring (3) which fix the removable bronze bush (1).
Push in order to extract this piece.

Assembly:

Having machined the removable bush according to valve stem dimensions, refit the drive bus (1) into the output shaft bore, align the keyway (2) in its output shaft shape.
Refit the retaining ring (3).




Figure 1

OUTPUT TYPE A Size F-10/F-16/F-25 (ISO 5210)

Disassembly:

Push and press the removable bronze bush (2) in order to extract the cover (4), axial bearings (3) and removable bronze bush (2)

Assembly:

Having machined the removable bronze bush according to valve shaft, clean thoroughly this piece. Apply grease on axial bearings and discs (3). Assemble axial disc on removable bush (2), finally insert the cover (4). Check O-rings on cover.

Apply grease on. Insert the removable bush on output type A base casting unit and output shaft, notice that dog coupling (Tooth) on bushing should match with actuator hollow output shaft (1). Verify O-ring (4).

For maintenance, grease can be supply thought grease nipple (5).




Figure 2

OUTPUT TYPE A Size F-14 (ISO 5210)

Disassembly

- Remove retaining ring (5) and unscrew the stop ring (4) employing a suitable tool.
- Push and press the removable bronze bush (1) in order to extract it.

Assembly:

- Having machined the removable bush according to valve stem dimensions, refit the drive bus (1) into the output shaft bore (3), align the keyway (2) in its output shaft shape.
- Screw the stop ring (4) employing a suitable tool.
- Refit the retaining ring (5).




Figure 3

OUTPUT TYPE B3 Size F-07/F-10/F-14/F-16/F-25 (ISO 5210)

Disassembly:

- Employing a suitable tool, remove the retaining ring (4) which fix the removable steel bush (1).
- Push in order to extract this piece.

Assembly:

- Having machined the removable steel bush according to valve stem dimensions, refit the drive bus (1) into the output shaft bore, align the keyway (2) in its output shaft shape.
- Refit the retaining ring (4).




Figure 4

OUTPUT TYPE B0 Size F-10 / F-14

B0 output type is supplied, already machined, according to dimensions published in technical datasheets.

Disassembly:

- Employing a suitable tool, remove the retaining ring (3) which fix the removable steel bush (1). Removable bush is located inside of output shaft (2)
- Push in order to extract this piece.

Assembly:

- Having machined the removable steel bush according to valve stem dimensions, refit the drive bus (1) into the output shaft bore
- Refit the retaining ring (3).




Figure 5










APENDIX: FASTEN BOLTS (CLASS 8.8)


BOLT	FRICION FACTOR		
	LOW	MEDIUM	HIGH
M4	4.2	6	8
M6	6.2	8.2	10
M8	15	21	24
M10	30	41	48
M12	49	68	85
M14	85	108	130
M16	130	165	200
M18	170	240	280
M20	240	340	410
M30	800	1150	1350
M36	1450	2050	2400

Torque values in N.m
Steel bolts class 8.8

WIRING DIAGRAMS, TERMINAL PLANS, LEGENDS AND SYMBOLS.

For further technical information, consult CENTORK technical datasheet or contact directly with CENTORK. CENTORK address can be found printed on manual covers.

SYMBOL	DESCRIPTION	TECHNICAL FEATURES																				
	FPC: CLOSE torque microswitch.	<ul style="list-style-type: none"> Microswitch with silver contacts Type of contact: 1 NA / 1 NC Protection degree: IP67 Contacts: One fast acting Mech. Life: $5 \cdot 10^6$ Electr. live: $5 \cdot 10^6$ Microswitch circuits NO+NC contacts, only the same potential can be connected through both circuits. For different potentials, two double microswitches must be used. 																				
	FPA: OPEN torque microswitch.																					
	FRC: CLOSE limit microswitch. (CLOSE end position)																					
	FRA: OPEN limit microswitch. (OPEN end position)																					
	BLK: Movement signalling microswitch. As actuator output shaft rotates or moves, a cam acts and switches ON-OFF this BLK microswitch.																					
	POT: Precision Potentiometer	<table border="1"> <thead> <tr> <th rowspan="2">Silver contacts</th> <th colspan="3">AC</th> <th colspan="3">DC</th> </tr> <tr> <th>30V</th> <th>125V</th> <th>250V</th> <th>30V</th> <th>125V</th> <th>250V</th> </tr> </thead> <tbody> <tr> <td>Resistance</td> <td>8A</td> <td>6A</td> <td>5A</td> <td>2A</td> <td>0.6A</td> <td>0.4A</td> </tr> </tbody> </table> <ul style="list-style-type: none"> 10 kOhms (other values on request). Ohmic value tolerance : $\pm 20\%$ std. ($\pm 10\%$ optional). Linearity : $< 1\%$. Power : 1W max. Turning angle : $340^\circ \pm 5\%$ Life : 106 cycles. Temperature range : -55°C , $+125^\circ\text{C}$.. <p>Safety parameters:</p> <ul style="list-style-type: none"> Pi: 804 mW for T4 Pi: 314 mW for T5 	Silver contacts	AC			DC			30V	125V	250V	30V	125V	250V	Resistance	8A	6A	5A	2A	0.6A	0.4A
Silver contacts	AC			DC																		
	30V	125V	250V	30V	125V	250V																
Resistance	8A	6A	5A	2A	0.6A	0.4A																
	TPS: 4-20 mA transmitter (2 wires) EEX ia IIC T6/T5/T4 according to LCIE 90.C6099X	<p>Features of intrinsically safe power source of Transmitter should not exceed:</p> <table> <tr> <td>U: 30 V</td> <td>i.e. PU \leq</td> <td>0,82 W</td> </tr> <tr> <td>U: 27 V</td> <td>i.e. PU \leq</td> <td>0,98 W</td> </tr> <tr> <td>U: 24 V</td> <td>i.e. PU \leq</td> <td>0,99 W</td> </tr> <tr> <td>U: 21 V</td> <td>i.e. PU \leq</td> <td>0,87 W</td> </tr> <tr> <td>U: 18 V</td> <td>i.e. PU \leq</td> <td>0,75 W</td> </tr> </table> <p>Temp. classification: T6, Tamb$<50^\circ\text{C}$ T5, Tamb$<65^\circ\text{C}$ T4, Tamb$<80^\circ\text{C}$</p>	U: 30 V	i.e. PU \leq	0,82 W	U: 27 V	i.e. PU \leq	0,98 W	U: 24 V	i.e. PU \leq	0,99 W	U: 21 V	i.e. PU \leq	0,87 W	U: 18 V	i.e. PU \leq	0,75 W					
U: 30 V	i.e. PU \leq	0,82 W																				
U: 27 V	i.e. PU \leq	0,98 W																				
U: 24 V	i.e. PU \leq	0,99 W																				
U: 21 V	i.e. PU \leq	0,87 W																				
U: 18 V	i.e. PU \leq	0,75 W																				
	M1 A.C. motor (single and three-phase)	<ul style="list-style-type: none"> Squirrel cage motor. Isolation class F. Main power supply: See motor nameplates. Main voltage supply tolerance: $\pm 5\%$ 																				
	TRM: Motor thermal protection via thermostatic switches (PTC thermistors on request).	<ul style="list-style-type: none"> The thermo-switches will open the circuit when the temperature of the windings reach 140°C and will close it when the temperature drops under 120°C. <table border="1"> <thead> <tr> <th rowspan="2"></th> <th colspan="2">AC 250V / 50-60Hz</th> <th colspan="3">DC</th> </tr> <tr> <th>Cos $\varphi = 1$</th> <th>Cos $\varphi = 0.6$</th> <th>60V</th> <th>42V</th> <th>24V</th> </tr> </thead> <tbody> <tr> <td>current</td> <td>2 A</td> <td>1.2 A</td> <td>1A</td> <td>1.2A</td> <td>1.8A</td> </tr> </tbody> </table>		AC 250V / 50-60Hz		DC			Cos $\varphi = 1$	Cos $\varphi = 0.6$	60V	42V	24V	current	2 A	1.2 A	1A	1.2A	1.8A			
	AC 250V / 50-60Hz			DC																		
	Cos $\varphi = 1$	Cos $\varphi = 0.6$	60V	42V	24V																	
current	2 A	1.2 A	1A	1.2A	1.8A																	



CIERRE/APERTURA POR LIMITE DE RECORRIDO
 -En caso de superacion de par cortamos cierre/apertura.
 -Si se supera par permite volver a intentar cierre/apertura realizando previamente movimiento contrario al que origino superacion de par

OPEN/CLOSE BY LIMIT SWITCHING
 -Case of overtorque, stops open/close action.
 -Case of overtorque, allows open/close action after having done close/open action.

MODIFICACION	FECHA	DIBUJADO	FECHA	FIRMA
A Permite A/C después de sup. de par	15/12/97		01/06/99	EV
B	-	REVISADO		
C	-	VERIFICADO		
D	-	ESCALA		
E	-			
F	-			
G	-			

gontork
 ACTUADOR INTEGRAL


CIERRE/APERTURA POR LIMITE DE RECORRIDO
OPEN/CLOSE BY LIMIT SWITCHING

Propiedad de CENTRALAR S.A. prohibido su utilizacion
 reproduccion y distribucion sin autorizacion expresa por escrito

RECORRIDO EN OTRAS ZONAS SIN INDICACION

TOLERANCIAS GENERALES DIMENSIONALES AGLIEROS: H12
 EJES: h12, ROSCAS: GRADO MEDIO, LONGITUDES: Js12

FORMATO N° DE PLANO: A3
 N° DE PLANO: D0015X2
 HOJA N°: 1 de 1



CIERRE/APERTURA POR LIMITE DE RECORRIDO
 -En caso de superacion de par cedamos cierre/apertura.
 -Si se supera por permite volver a intentar cierre/apertura realizando previamente movimiento contrario al que origino superacion de par

OPEN/CLOSE BY LIMIT SWITCHING
 -Case of overtorque, stops open/close action.
 -Case of overtorque, allows open/close action after having done close/open action.

CIERRE VALVULA CLOSURE VALVE

ABRIR VALVULA OPEN VALVE

VAHVULA CERRADA VALVE CLOSED

VAHVULA ABIERTA VALVE OPENING

SUPERACION DE PAR EN EL CIERRE OVERTORQUE IN CLOSE DIRECTION

SUPERACION DE PAR EN LA APERTURA OVERTORQUE IN OPEN DIRECTION

REPRODUCCION EN OTRAS ZONAS SIN INDICACION

PROPIEDAD DE CENTRALAR S.A. prohibida su utilizacion reproduccion y distribucion sin autorizacion expresa por escrito

MODIFICACION	FECHA	FECHA	FECHA
A QUITAR EL CONDENSADOR DEL MOTOR	01/06/99	07/03/01	07/03/01
B	-	REVISADO	IM
C	-	VERIFICADO	-
D	-	ESCALA	-
E	-	-	-
F	-	-	-
G	-	-	-

CIERRE VALVULA CLOSURE VALVE	ABRIR VALVULA OPEN VALVE
KM1	KM2
KM3	KM4
KM2	KM1
KM1	KM3
KM3	KM4
KM4	KM2

VAHVULA CERRADA VALVE CLOSED	VAHVULA ABIERTA VALVE OPENING
L1	L2
L2	L3
L3	L4
L4	L1

CIERRE/APERTURA POR LIMITE DE RECORRIDO	OPEN/CLOSE BY LIMIT SWITCHING
A3	A3
D0043X2	D0043X2
N.º de 1	N.º de 1

TOLERANCIAS GENERALES DIMENSIONALES AGUJEROS: H12 EJS: h12. ROSCAS: GRADO MEDIO. LONGITUDES: JS12
FORMATO
N.º DE PLANO
HOLA

REPRODUCCION EN OTRAS ZONAS SIN INDICACION
RO.3

Propiedad de CENTRALAR S.A. prohibida su utilizacion reproduccion y distribucion sin autorizacion expresa por escrito
FORMATO
N.º DE PLANO
HOLA

APENDIX: CERTIFICATES.



Declaración de Conformidad

Centork Valve Control S.L. declara que los actuadores eléctricos para atmósferas potencialmente explosivas, series:

140A. 141A.
140B. 141B.

han sido diseñados, producidos como accionamientos eléctricos para operar válvulas industriales para usos en atmósferas potencialmente explosivas, según el certificado CE de tipo LOM03ATEX 2126 X, y de acuerdo con los requerimientos de las Directivas CE reseñadas,

Directiva 98/37/CE Máquinas, 22 de Junio 1.998
Directiva 73/23/CE Directiva de Baja Tensión, 19 Febrero 1.973
Directiva 94/9/CE Aparatos y sistemas de protección para usos en atmósferas potencialmente explosivas, 23 Marzo 1.994

aplicándose las siguientes normas,

<i>ISO 5210 Sept. 1.991</i>	<i>EN 50.014 Dic.1.999</i>	<i>EN 60.204-1 Febr. 1.999</i>
<i>ISO 5211 Febr. 2.001</i>	<i>EN 50.018 Dic. 2.001</i>	<i>EN 60529 Marzo 2.000</i>
<i>EN 292-1 Abr. 1.993</i>	<i>EN 50.019 Ene. 2.002</i>	<i>DIN VDE 0100 Ene 1.997</i>
<i>EN 292-2 Abr.1.993</i>	<i>EN 50.020 Sept. 2.003</i>	<i>DIN VDE 0530 Dic. 1982</i>

Si el mencionado aparato es montado en una máquina o instalado junto con otras máquinas o dispositivos, está prohibida la puesta en marcha de la máquina o conjunto de máquinas hasta que se verifique su conformidad con los requisitos de las directivas aplicables, así como con los requisitos y normas de seguridad aplicables.

Esta declaración queda sin efecto si el aparato ha sido modificado sin nuestra autorización escrita.

San Sebastián, 3 de Octubre de 2.003



Francisco Lazcano
-Director general-

(Sede social)
Centork Valve Control S.L.
Portuetxe 23-25
San Sebastián 20.018 ESPAÑA

(Centro fabricación)
Centork Valve Control S.L.
Zikuñaga 19
Hernani 20.120 ESPAÑA



(1) **EC-TYPE EXAMINATION CERTIFICATE**

(2) Equipment or protective system intended for use in potentially explosive atmospheres
Directive 94/9/EC

(3) EC-Type Examination Certificate number **LOM 03ATEX2126 X**

(4) Equipment or Protection System Electrical actuators
Type CENTORK 14**.*

(5) Applicant: Centork Valve Control, S.L.

(6) Address: Cl. Portuetxe, 23
20018-SAN SEBASTIÁN
SPAIN

(7) This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) Laboratorio Oficial J.M. Madariaga (LOM), notified body number 0163 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.
The examination and test results are recorded in confidential report nr. **LOM 03.372 LP**

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
— Standards **EN 50014:1997 + A1:1999 + A2:1999**
EN 50018:2000 + A1:2002
EN 50019:2000
EN 50020:2002

(10) If the sign X is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-Type Examination Certificate relates only to the design and construction of this specified equipment or protective system in accordance with the Directive 94/9/EC. Further requirements of the Directive applies to the manufacture and supply of this equipment or protective system. These are not covered by this certificate.

(12) The marking of the equipment or protective system shall include the following:

II 2 G EEx de IIC T4..T5 / EEx de IIC T4...T5
Ta: -20 °C /+70 °C

Madrid, 29 September 2003

Carlos Fernández Ramón
DIRECTOR OF THE LABORATORY



Angel Vega Remesal
Head of TEX area

(This document may only be reproduced in its entirety)
This Certificate is a translation from the original in Spanish. The LOM liability applies only on the Spanish text





LABORATORIO OFICIAL J. M. MADARIAGA

(A1) SCHEDULE

(A2) EC-Type Examination Certificate: **LOM 03ATEX2126 X**

(A3) Description of equipment or protective system

Electrical actuators for valves composed by a flameproof electrical motor, gear box, control and signalling devices, increased safe connection box that include, optionally, intrinsic safe terminals; the last ones are marked and segregated from power terminals.

Electrical motor is protected with switch-off thermo-devices having two ranges: 120 °C and 140 °C that correspond to T4 or T5 temperature classes, respectively.

Control and signalling devices include flameproof type of protection micro-switches with certificate LCIE 02ATEX0034U.

Optionally are included intrinsical safe devices for position measurement in two versions

- a) Potentiometer, with three wire connection
Parameters: Pi: 804 mW para T4
Pi: 314 mW para T5
- b) 4-20 mA transmitter with certificate LCIE 02ATEX6073 X, with 2 wire external connection and internal connection to potentiometer
Parameters: same as indicated in certificate LCIE 02ATEX6073 X for the external connection

Different versions can have A.C. triphase electrical motors and also monophasic motors as follows:

Thriphase motors


- Power (kW): 0,022 - 0,045 - 0,09 - 0,18 - 0,37 - 0,55 - 0,75 - 1,1 - 1,5 - 2,2 - 3
- Voltage at 50 Hz (V): 230 - 380/415 - 500
- Voltage at 60 Hz (V): 230 - 440/460

Monophase motors

- Power (kW): 0,022 - 0,045 - 0,09 - 0,18 - 0,37 - 0,55
- Voltage at 50 Hz (V): 220/240
- Voltage at 60 Hz (V): 110/120

Type nomenclature

14 ** * * * *



(This document may only be reproduced in its entirety)

This Certificate is a translation from the original in Spanish. The LOM liability applies only on the Spanish text



LABORATORIO OFICIAL J. M. MADARIAGA

(A1) SCHEDULE

(A2) EC-Type Examination Certificate: **LOM 03ATEX2126 X**

(A4) Tets report nr. **LOM 03.372 SP**

(A5) Special conditions for a safe use

- Electrical motor must be protected by means pf the appropriated circuit connected to protection thermal devices

(A6) Individual tests

Each manufactured motor must be submitted to pressure tests at 930 kPa according the paragraph 15.1.3 of the standard EN 50018:2000

(A7) Essential Health and Safety Requirements

Explosion safe requirements are covered by application of the standards indicated in page 1/3 of this certificate.

(A8) Descriptive documents

	Rev.	Date
- Description	-	2003-05-20
- Drawings nr.	00034XA	A
	00035XA	A
	00036XA	A
	00037XX	-
	00038XX	-
	00056XA	A
	00130XX	-
	60974XA	A



(This document may only be reproduced in its entirety)

This Certificate is a translation from the original in Spanish. The LOM liability applies only on the Spanish text

12. NOTES



CENTORK Valve Control S.L.

Camino Portuetxe, 23 SAN SEBASTIAN 20.018 (SPAIN)
Telf.: +34.943.31.60.31 Fax.: +34.943.21.76.75
Email: actuator@centork.com <http://www.centork.com>

1497.MANE140AX001

Edition: 12.04