# FIRE CHECK VALVE YANGIN ÇEKVALF



The Gruvlok 78FP UL/ULC Listed and FM Approved Check Valve is a compact, cost-effective valve, designed for use in grooved-end pipe fire protection systems and related equipment. Valves are to be used in conjunction with grooved pipe and pipe couplings that are listed or approved for fire protection systems.

## PRESSURE RATING:

2" through 12" 78FP UL/ULC Listed and FM Approved Check Valves have a maximum working pressure of 300 PSI (20.7 bar).

#### **DESIGN FEATURE:**


In a full open position the 78FP UL/ULC Listed and FM Approved rubber faced swing clapper is held tightly against the valve body, out of the flow stream, to provide maximum flow area and prevention of clapper flutter. The spring loaded clapper design produces quick, non-slam closure before flow reversal can occur, which provides a leak free sealing of back pressures as low as 1 PSI (0.07 bar) equivalent to 28" water head, meeting FM requirements for an anti-water-hammer check valves.



#### APPLICATIONS:

Appropriate for use in fire protection connections such as:

- Fire Department pumper to sprinkler systems
- Public water supplies to automatic sprinkler systems
- Fire pump discharges and by-pass
- Gravity and pressure tanks



# **MATERIAL SPECIFICATIONS**

BODY: Ductile Iron conforming to ASTM A-536, Grade 65-45-12

COATINGS: Rust inhibiting paint on exterior Color: BLACK

CLAPPER: 2"- 5" Type 304 or 302 Stainless Steel to ASTM A-167 6"-12" Ductile Iron conforming to ASTM A-536, Grade 65-45-12

# CLAPPER FACING: Grade "E" EPDM

-40°F to 230°F (Service Temperature Range)(-40°C to 110°C) Recommended for water service, diluted acids, alkalies solutions, oil-free air and many chemical services.

NOT FOR USE IN PETROLEUM APPLICATIONS.

SEAT RING: Type 304 Stainless Steel conforming to ASTM A-123, ASTM A-213, ASTM-A 312 or ASTM A-269

SPRING: Type 302 Stainless Steel conforming to ASTM A-313

HINGE PIN: Type 304 or 302 Stainless Steel conforming to ASTM A-580
HINGE PIN BUSHINGS: Sintered Bronze conforming to ASTM B-438
HINGE PIN PLUGS AND DRAIN PLUGS: Cast Iron conforming

to ASTM A-126 Class A.



Adres: İkitelli OSB Eskoop Sanayi Sitesi C8 Blok No:549 Başakşehir / İstanbul Türkiye Tel: 212 297 57 30 Fax: 212 297 57 33 E-mail: dd@ddvalve.comWeb: www.ddvalve.com

# FIRE CHECK VALVE YANGIN ÇEKVALF





## FLOW DATA:


The approximate friction losses, based on the Hazen and Williams formula, expressed in equivalent length of pipe is given at right. The friction losses have been calculated on the basis of flow rates typically used with each size valve.


# IMPORTANT NOTE:

Check valve life may be shortened and system damage may occur if check valves are installed too close to a source of unstable flow. Check valves must be installed at a reasonable distance away from pumps, elbows, expanders, reducers or other similar devices. Sound piping practices dictate a minimum of five (5) times the pipe diameter for general use. Distances between three (3) and five (5) diameters are allowable provided the flow velocity is less than 8 feet per second. Distances less than 3 diameters are not recommended.









| SERIES 78FP CHECK VALVE<br>FLOW DATA - FRICTION LOSS (FT. OF PIPE) |        |         |         |         |         |         |         |  |  |  |  |
|--------------------------------------------------------------------|--------|---------|---------|---------|---------|---------|---------|--|--|--|--|
| Valve Size                                                         | 0.0.   |         | C=100   |         | C=120   |         |         |  |  |  |  |
|                                                                    |        | Sch. 10 | Sch. 30 | Sch. 40 | Sch. 10 | Sch. 30 | Sch. 40 |  |  |  |  |
| In./mm                                                             | In./mm | R/m     | Ft./m   | Ft/m    | Ft/m    | Pt/m    | Ft./m   |  |  |  |  |
| 2                                                                  | 2.375  | 10      | 2-5     | 8       | 14      | _       | 11      |  |  |  |  |
| 50                                                                 | 60.3   | 3.0     | - 4     | 2.4     | 4.3     | -       | 3.4     |  |  |  |  |
| 21/2                                                               | 2.875  | 14      |         | 10      | 20      | 1200    | 15      |  |  |  |  |
| 65                                                                 | 73.0   | 4.3     |         | 3.0     | 6.1     | -       | 4.6     |  |  |  |  |
| 3                                                                  | 3.500  | 17      |         | 12      | 23      | -       | 17      |  |  |  |  |
| 80                                                                 | 88.9   | 5.2     |         | 3.7     | 7.0     | -       | 5.2     |  |  |  |  |
| 4                                                                  | 4.500  | 17      | 1 s.—   | 13      | 23      |         | 18      |  |  |  |  |
| 100                                                                | 114.3  | 5.2     | 1=1     | 4.0     | 7.0     | 142     | 5.5     |  |  |  |  |
| 5                                                                  | 5.563  | 14      |         | 11      | 20      |         | 15      |  |  |  |  |
| 125                                                                | 141.3  | 4.3     |         | 3.4     | 6.1     | _       | 4.6     |  |  |  |  |
| 6                                                                  | 6.625  | 23      | 2-2     | 19      | 33      | 1       | 26      |  |  |  |  |
| 750                                                                | 168.3  | 7.0     | 1,50    | 5.8     | 10.1    |         | 7.9     |  |  |  |  |
| 8                                                                  | 8.625  | 35      | 32      | 30      | 50      | 45      | 43      |  |  |  |  |
| 200                                                                | 219.1  | 70.7    | 9.8     | 9.7     | 15.2    | 13.7    | 13.1    |  |  |  |  |
| 10                                                                 | 10.750 | 28      | 25      | 24      | 40      | 36      | 34      |  |  |  |  |
| 250                                                                | 273.1  | 8.5     | 7.6     | 7.3     | 12.2    | 11.0    | 10.4    |  |  |  |  |
| 12                                                                 | 12.750 | 31      | 28      | 26      | 44      | 39      | 37      |  |  |  |  |
| 300                                                                | 323.9  | 9.4     | 8.5     | 7.9     | 13.4    | 11.9    | 11.3    |  |  |  |  |

| SERIES 78FP CHECK VALVE     |        |                    |             |             |             |             |             |             |                                |   |       |
|-----------------------------|--------|--------------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------------------------|---|-------|
| Valve<br>Size<br>In./DN(mm) | 0.D.   | Nominal Dimensions |             |             |             |             |             |             |                                |   |       |
|                             |        | A<br>In./mm        | B<br>In./mm | (<br>In./mm | D<br>In./mm | E<br>In./mm | F<br>In./mm | G<br>In./mm | Approx.<br>Wt. Ea.<br>Lbs./Kg. |   |       |
|                             |        |                    |             |             |             |             |             |             |                                | 2 | 2.375 |
| 50                          | 60.3   | 171                | 60          | 36          | 44          | 114         | 81          | 111         | 3.4                            |   |       |
| 21/1                        | 2.875  | 71/4               | 21/16       | 11/16       | 1%          | 317/16      | 3%          | 41/2        | 10.5                           |   |       |
| 65                          | 73.0   | 184                | 61          | 39          | 44          | 96          | 92          | 114         | 4.8                            |   |       |
| 3                           | 3.500  | 7%                 | 2%          | 2           | 13%         | 41/4        | 311/se      | 411/4       | 11.5                           |   |       |
| 80                          | 88.9   | 197                | 67          | 51          | 46          | 103         | 93          | 125         | 5.2                            |   |       |
| 4                           | 4.500  | 8%                 | 31/4        | 21/4        | 21/2        | 51/16       | 41/4        | 6           | 13.5                           |   |       |
| 100                         | 114.3  | 206                | 79          | 57          | 64          | 128         | 108         | 152         | 6.1                            |   |       |
| 5                           | 5.563  | 9%                 | 31/2        | 2%          | 21/16       | 513/16      | 41/4        | 6%          | 19.0                           |   |       |
| 125                         | 141.3  | 248                | 89          | 70          | 61          | 147         | 117         | 171         | 8.6                            |   |       |
| 6                           | 6.625  | 121/4              | 41/4        | 31/4        | 31/6        | 61/4        | 63/4        | 81/2        | 33.5                           |   |       |
| 150                         | 168.3  | 324                | 108         | 84          | 79          | 159         | 171         | 216         | 15.2                           |   |       |
| 8                           | 8.625  | 14%                | 51/4        | 315/14      | 4           | 515/14      | 8           | 101/4       | 59.0                           |   |       |
| 200                         | 219.1  | 365                | 128         | 100         | 102         | 150         | 203         | 260         | 26.8                           |   |       |
| 10                          | 10.750 | 18                 | 6%          | 45%         | 41/16       | 67/4        | 91/4        | 1211/14     | 130.0                          |   |       |
| 250                         | 273.1  | 457                | 160         | 125         | 115         | 175         | 233         | 322         | 59.0                           |   |       |
| 12                          | 12.750 | 21                 | 75/4        | 6           | 51/16       | 71/4        | 10%         | 14%         | 183.0                          |   |       |
| 300                         | 323.9  | 533                | 185         | 152         | 128         | 184         | 264         | 375         | 83.0                           |   |       |



Adres: İkitelli OSB Eskoop Sanayi Sitesi C8 Blok No:549 Başakşehir / İstanbul Türkiye Tel: 212 297 57 30 Fax: 212 297 57 33 E-mail: dd@ddvalve.comWeb: www.ddvalve.com